

Section 1.

Section 1. Any flammable liquid or gasoline storage tank installed below the ground under license duly granted by the Select Board will be tested for leakage at the expense of the owner upon installation, and according to the following schedule, the date of which shall be determined by the license date or the date of installation whichever is later. Day of installation Every 5 years up to 20 years Every 2 years up to 30 years Annually unless the Fire Chief determines that conditions indicate more frequent testing be done.

Such testing will be done under the supervision of the Chief of the Fire Department using the Kent/Moore Test Method. The tank or tanks shall be removed by the owner, at no expense to the Town, if they should fail the test, 14-42 Inserted under article 74, ATM 1971 (see also Article XIV, Section 13 of these By-Laws). Amended under article 25, motion 1 , ATM April 24, 2000, disallowed by Attorney General. 14-43 Inserted under article 53, ATM 1973. Amended under article 31, ATM 2008. 14-44 Inserted under article 41, ATM 1980. 68

or at anytime when they shall become a hazard because of leakage or otherwise, in the opinion of the Chief of the Fire Department.

Independent reference excerpt. Consult the official town PDF for authoritative formatting and subsequent amendments.

Source: <https://www.town.canton.ma.us/DocumentCenter/View/13507/GENERAL-BY-LAWS-2025#page=68>